







Stacked Alcohol Display
Length 2m

Height 1.5m Capacity 3.0m<sup>2</sup>

Total Capacity = 111.24m<sup>2</sup>

## **LEGEND**

SD

SMOKE DETECTOR



**EMERGENCY LIGHT** 



CARBON DIOXIDE EXTINGUISHER



FOAM EXTINGUISHER



WATER EXTINGUISHER



**BREAK GLASS UNIT** 

Emergency lighting system to comply with British Standard 5266: Part 1: 1999. (Maintained- 2hour duration) and BS EN 1838:1999 (or BS 5266-7: 1999)

Firefighting Equipment to comply with British Standard EN3, British Standard 7863: 1996, British Standard 5306-3: 2000 and British Standard 5306-8: 2000

Signs and notices to comply with the Health and Safety (Safety Signs and Signals)
Regulations 1996 and / or British Standard 5499: Part 1: 1990.

Any information contained in this drawing which is not required by regulation 5 of SSI 2007/452 is included for illustrative purposes only and does not form part of the layout plan for the purposes of the said regulation or the Licensing (Scotland) Act 2005

## smithfindlay:architects

2 Merkland Street T 0141 334 4995 E design@smithfindlay.co.uk Glasgow G11 6DB F 0141 334 8186 W www.smithfindlay.com

## project:

38 PORTLAND STREET, TROON STORE NO:-

## title:

LICENSE APPLICATION LAYOUT PLAN

scale: 1:100@A3	drawn: 3 TW	checked:	<b>date:</b> 01/15
job:	drawir	drawing number:	
1338	L(	L(10)1	