



Low level wall  
**SOUTH HARBOUR STREET**

Rev B Modified to suit amended building approval.  
 Rev C Counter modified, booth seating adjacent leading to raised area modified.  
 Rev D Cleaners store changed to toilet cubicle and gate added externally.

- The following activities/facilities are available throughout:
- A Conference
  - B Indoor Sports
  - C Bar/Mateli
  - D Social functions
  - E Recorded Music
  - F Live performances
  - G Dance facilities
  - H Films
  - I Gaming
  - J Indoor Sports
  - K Refreshed Sport
  - L Clubby Events

**EMERGENCY LIGHTING**  
 NEW EMERGENCY LIGHTING TO BE INSTALLED AND BE IN ACCORDANCE WITH BS 5268, WITH CONNECTION TO EXISTING STAIR SYSTEMS AND THOROUGHLY TESTED.

**FURNISHINGS**  
 NEW UPHOLSTERY CONVENIENS TO COMPLY WITH BS 7176 PART 2, ORIG TEST 5. CARPETS TO HAVE A LOW RADIUS OF EFFECTS OF IRRADIATION (UP TO 30mm) WHEN TESTED TO BS 4790. CURTAINS AND DRAPES TO COMPLY WITH TYPE B PERFORMANCE OF BS 5837 PART 2. FURNISHINGS TO COMPLY WITH IRRADIATION SOURCE 0 AND ORIG SOURCE 5 OF BS 5832. FURNISHINGS TO BE TESTED IN ACCORDANCE WITH BS 5851 TO BE CARRIED OUT PRIOR TO LABORATORY TEST IF FABRIC MATERIALS ARE USED. A COPY OF THE LABORATORY TEST REPORT, COMPLAINING COMPLIANCE OF THE FURNISHINGS COMPATIBLE WITH BS 5851, IS TO BE FORWARDED TO THE FIRE AUTHORITY IF NECESSARY.

**FIRE ALARM SYSTEM**  
 THE PREMISES ARE TO BE PROTECTED BY A FIRE ALARM SYSTEM IN ACCORDANCE WITH BS 5839 PART 1 AND AUTOMATIC AND MANUAL WARNING OF FIRE. ALL NEW COMPONENTS TO BE INTERGRATED WITH EXISTING FIRST FLOOR SYSTEM AND CHECKED. ALL NEW ACQUISITION POINTS OR SOUNDERS TO BE INSTALLED ON SITE FOLLOWING FIRE OFFICERS RECOMMENDATION.

**FIRE CLOSING EQUIPMENT**  
 EQUIPMENT SHALL BE IN ACCORDANCE WITH BS 5306 AND BS 5423 AND BE INSTALLED TO CURRENT FIRE SAFETY EQUIPMENT SHALL BE IN ACCORDANCE WITH BS 5306 AND BS 5423 AND BE INSTALLED TO CURRENT FIRE SAFETY EQUIPMENT.

**FIRE DOORS**  
 ALL FIRE SIGNS TO BE MOUNTED AT EYE LEVEL ON BOTH FACES OF ALL FIRE DOORS TO COMPLY WITH BS 5498 EXISTING.

**FIRE DOORS**  
 NEW DOORS TO BE -  
 - HALF HOUR FLOORS FIRE RESISTING, SELF CLOSING DOORS IDENTIFIED AS ONE HOUR FLOORS FIRE RESISTING, SELF CLOSING DOORS IDENTIFIED AS NOTE - LOCKABLE DOORS HAVE TO HAVE INTERNAL, THUMB TURN, FIRE DOOR SMOKE IN ACCORDANCE WITH BS 5499 AND BE INSTALLED AS NECESSARY.

**HEAT AND SMOKE DETECTION**  
 ALL NEW DETECTION EQUIPMENT TO BE INSTRUCTED ON SITE FOLLOWING FIRE OFFICERS RECOMMENDATIONS.

This is the layout plan relative to the premises:  
 license application dated 15th October 2008  
 on behalf of Barracuda Film & Arts Limited  
 The Main Creek, 1478 New Bridge Street, Ayr,  
 KA7 7LX  
 R & J M Hill Brown & Co  
 IDMG No 167506/M Rev D)

Client  
**Barracuda Group**  
 Project  
**SMITH & JONES, Ayr**  
 Drawing Title

DEA Partnership LLP  
 Chartered Designers  
 Summerfield House  
 22 Woodlands Road  
 Middlesbrough TS1 3BE  
 T: 01642 227693  
 F: 01642 245394  
 E: mail@deapartnership.co.uk

Scale Date Drawing Number  
 1:100 04/07 1675/06/M